



- NOTE:
- 1 - CONCRETE, MINIMUM 28 DAYS STRENGTH TO BE 30Mpa -TYPE 50
  - 2 - REINFORCEMENT TO BE WELDED WIRE FABRIC TO CSA G30.3-1983
  - 3 - SUFFICIENT LAP STRENGTH FOR REINFORCEMENT SHOULD BE PROVIDED TO ENSURE CONTINUITY OF REINFORCEMENT.
  - 4 - MINIMUM CONCRETE COVER FOR REINFORCEMENT
    - A)30mm FOR OUTSIDE FACE OF BOX PAD
    - B)20mm FOR INSIDE FACE OF BOX PAD
  - 5 - MASS: 8935 Lbs / 4080 Kg
  - 6 - BASE IS SIZED TO ACCOMODATE 15KV - 25KV SWITCHGEAR
  - 7 - UNLESS OTHERWISE INDICATED, ALL DIMENSIONS ARE IN MILLIMETRES
  - 8 - LIFTING ANCHOR IS 2.5 TON 3 3/8" LENGTH UNLIFTER

Fortis # 755-0561


**SOCP**  
 SOUTH OKANAGAN  
 CONCRETE PRODUCTS LTD  
 TEL: 250-495-7556  
 socp@socp.ca  
 www.socp.ca  
 Box 419, 11602 - 115 st Ossoyoos, BC V0H 1V0 FAX: 250-495-3556

1595 Fortis Switch  
Cubicle Base

Product #  
**1129**