



NOTES:

1. THE PLASTIC PIPE OR CONDUIT AND CAP MUST BE INSTALLED TO INSULATE THE PIPE AND THUS PREVENT TRANSFER OF DANGEROUS TOUCH POTENTIAL IN THE EVENT OF THE FAULT.
2. PLASTIC CAP SHALL BE GLUED TO PLASTIC PIPE OR CONDUIT WITH CEMENT TO FORM A WATERPROOF JOINT
3. BOLLARDS SHALL BE PLACED SO AS NOT TO OBSTRUCT ANY DOORS NOR RESTRICT THE OPERATION OF THE UNIT.
4. ALL DIMENSIONS ARE IN MILLIMETERS.
5. PRECAST CONCRETE BASE TO BE 6X6-6/6 RE-ENFORCEMENT MESH.
6. APPROXIMATE WEIGHT: 440 kg



TEL: 250-495-7556
socp@socp.ca
www.socp.ca

1589 Fortis Vehicle Bollard

Product #

1140